



**ADDENDUM NO. 3
REQUEST FOR INFORMATION
BID 5006: PAINTING OF STRUCTURAL AND DECORATIVE
STEEL AT NINE DISTRICT SCHOOL SITES**

Proposal Due Date Remains:

October 29, 2009 2:00 PM

QUESTIONS AND ANSWERS:

Q1: Project Specification Section 3.2, PREPARATION OF SURFACE, Paragraph 3.7A states 'Abrasive blast surface to level SSPC-SP6 before applying primer. Is this necessary?

A1: Yes.

Q2: Why is oil based product being used on galvanized metal? Wouldn't an acrylic based product give better flexibility?

A2: Use oil based product as specified.

Q3: The Schedule calls for 27 Calendar Days. Will there be rain days granted in this Schedule?

A3: Be advised, the Completion Time for the Work of this Contract has been changed to 33 Calendar Days. Weather days that may prolong the Contract beyond the 33 Calendar Days may be granted if the weather affects drying time and product application.

Q4: Are there Lead or Asbestos issues on any surfaces scheduled for painting on the nine schools listed?

A4: No. The schools in this contract were constructed in 2004.

**ADDENDUM NO. 3
BID 5006: PAINTING OF STRUCTURAL AND DECORATIVE STEEL AT NINE
DISTRICT SCHOOL SITES
PAGE 2**

Q5: Does the District use a particular window company for Window Replacement if needed?

**A5: Santa Maria Glass and Mirror Company
503 West Main Street
Santa Maria, CA 93458
(805) 925-8701
Contact: Dale Iliff**

Q6: Does the District use a particular fence company?

**A6: Fence Factory
2709 Santa Maria Way
Santa Maria, CA 93456
(805) 9285848**

Q7: Are the doors and doors frames to be painted on both sides on all sites or do some sites call for exterior side only?

A7: Doors are to be painted on both interior and exterior sides at all sites called out in the Contract. Door frames are to be painted to the exterior stop.

Q8: Please clarify if the metal window frames called out in the Contract will require painting on the interior frame as well.

Q8: The exterior window frames are included in the Scope of Work. Interior window frames are not included in the Scope of Work.

Addendum Number Three forms a part of the Contract Documents and modifies the Bidding Documents dated October 2009 as noted. Acknowledgement of receipt of Addendum Number Three in the space provided on the Bid Form is required. Failure to do so may result in the Bid being deemed Non-Responsive.

ALL OTHER REQUIREMENTS, TERMS AND CONDITIONS REMAIN THE SAME